

Transmission Lessons Learned from the Decarbonization of Minnesota's North Shore


Christian Winter – Minnesota Power
Minnesota Power Systems Conference
November 13, 2019



Overview

- Background
- Issues
 - Voltage Support & System Strength
 - Power Delivery Capability
 - Redundancy
- Summary

What is the North Shore Loop?



Transmission Impacts from Fleet Transition


- Voltage Support & System Strength
 -
 -
 -
- Power Delivery Capability
 -
 -
- Redundancy
 -
 -

Transmission Impacts from Fleet Transition

- Voltage Support & System Strength
 - Steady state voltage regulation
 - Dynamic reactive support (Voltage Stability, Damping)
 - Short circuit capability
- Power Delivery Capability
 -
 -
- Redundancy
 -
 -

Illustration: Voltage Support

Imagine the power system in Minnesota being supported by columns, representing baseload **generators that supply voltage support and system strength.**




★ Major Load Centers


Removing columns weakens
the support system

CONCLUSION: *Voltage Support & System Strength* presently provided by baseload generators needs to be retained or replaced. Location matters.


North Shore Loop Reactive Resources (2014)



North Shore Loop Reactive Resources (2015)



North Shore Loop Reactive Resources (2016)



Switched Capacitor Banks (MVAR)


Dynamic Voltage Support (MVAR)

Voltage Support Resources in the North Shore Loop
2016: Silver Bay & Tac Harbor Units Idled
 Total Static: 127 MVAR (No Change since 2014)
 Total Dynamic: 25 MVAR (-212 MVAR since 2014)


Taconite Harbor Voltage Regulation (2016)

Taconite Harbor 138 kV Bus Voltage


June 1, 2016 - December 31, 2016



North Shore Loop Reactive Resources (2017)




North Shore Loop Reactive Resources (2019)




Taconite Harbor Voltage Regulation (2019)

Taconite Harbor 138 kV Bus Voltage
May 1, 2019 - October 21, 2019




Silver Bay Voltage Regulation (2019)

Silver Bay 115 kV Bus Voltage
May 1, 2019 - October 29, 2019



North Shore Loop Voltage Stability




North Shore Loop Fault
Without North Shore STATCOM

Voltage Collapsed

Voltage Stability

Must provide sufficient dynamic (fast-responding) reactive support to ensure system voltage can recover after a fault event




North Shore Loop Fault
With STATCOM

Voltage Recovered

2021 SHA0 MISOLE_PASS2_TVA_CELL
BENCHMARK: BOSWELL_3 AND 4 ON
60 EACH MSC SCENARIO, SIG NSH-2H BF
SVC CAP. SIZE 1.0 PU
FILE: update10_svc_nsh-2h_60ea_r2p_Bmbah1.0UVSB0.39bn-0.8_10a.CUV

North Shore Loop Reactive Resources (2020+)



Switched Capacitor Banks (MVAR)

Dynamic Voltage Support (MVAR)



Voltage Support Resources in the North Shore Loop 2020+: Mesaba Junction Cap Banks (Planned)
 Total Static: 215 MVAR (+88 MVAR)
 Total Dynamic: 175 MVAR (-62 MVAR)

Transmission Impacts from Fleet Transition

- Voltage Support & System Strength
 - Steady state voltage regulation
 - Dynamic reactive support (Voltage Stability, Damping)
 - Short circuit capability
- Power Delivery Capability
 - Increased reliance on external sources
 - Increased power flow on incoming transmission lines
- Redundancy
 -
 -

Illustration: Power Delivery Capability


Today, a certain amount of power is provided by baseload generators at particular locations




When this power is **no longer supplied at the same locations**, a “hole” is created that must be filled

CONCLUSION: Replacement of power provided by existing generators may cause a need for transmission upgrades


Power Provided by Baseload Generators




Increased Reliance on External Sources



Strengthening the Forbes Source



Forbes: Critical Contingency




Solution: Forbes Transformer Addition

PROBLEM SOLVED:


- Re-establish a second 230/115 kV transformer at Forbes
- **NOW** the connection between 230 kV and 115 kV remains intact
- **ALSO** adds much-needed transformer capacity to support increased reliance on 230/115 kV connection




Forbes: Critical Contingency (Pre-Project)




Forbes: Critical Contingency (Post-Project)



Strengthening the Minntac Source




Minntac: Critical Contingency




Solution: Minntac Bus Reconfiguration

PROBLEM SOLVED:


- Add 3 new breakers & replace the existing breaker with a newer one
- Expand the Minntac 230 kV bus into a more reliable “ring” bus
- Relocate a transmission line to a different position on the bus
- **NOW** for any single breaker failure, one transmission line and one 230/115 kV transformer are still connected




Minntac: Critical Contingency (Pre-Project)



Minntac: Critical Contingency (Post-Project)




Increased Flow on Incoming Lines



Transmission Impacts from Fleet Transition

- Voltage Support & System Strength
 - Steady state voltage regulation
 - Dynamic reactive support (Voltage Stability, Damping)
 - Short circuit capability
- Power Delivery Capability
 - Increased reliance on 230/115 kV Sources
 - Increased power flow on 115 kV system
- Redundancy
 - Fewer sources available in the area
 - Limited options for mitigating issues

Redundancy: Hoyt Lakes End




Single Points of Failure leave the entire North Shore Loop served only from the Duluth end (140 miles away)

Low Voltage Weak System
"Baseload Issues"
Transmission O Redundancy

250 MW Peak Load

Baseload Support


Mesaba Junction 115 kV Project



Solution: Mesaba Junction 115 kV Project

- | | |
|--------------------------|------------------------------------|
| New Parallel 115 kV Line | Redundancy, Capacity |
| New Switching Station | Redundancy, Voltage Support |
| Voltage Conversion | Eliminate Single Points of Failure |

Redundancy: Duluth End




250 MW Peak Load



Maintenance/Prior Outage contingencies leave the entire North Shore Loop served only from the Hoyt Lakes end (140 miles away)

90 MW

Duluth 115 kV Loop Solution Alternatives



North Shore Loop Transmission Projects



Legend

- Local Baseload Generators
- 115 kV Lines/Substations
- 138 kV Lines/Substations
- 230 kV Lines/Substations