

"How **LOW** can you **GO**?"

CVR APPLIED AS DEMAND RESPONSE USING AMI METER DATA

Tom Guttormson, PE Principal Technology Engineer









130,000 member customers 1,000 square miles territory 44 substations 12.5 kV 9,000 miles of line 92% residential by customer System peak demand 550 MW Wholesale Power Supplier – Great River Energy



AGENDA

H

Conservation Voltage Reduction

- CVR for Demand Response Basis of Operation
- History at Connexus
- AMI Integration "Dynamic Voltage Reduction"
- Results, Issues, Lessons Learned





- 2000 Developed concept, initial field testing
- **2001 2002** Initial production trial 10 substations
- 2003 2012 Annual production summer months (June August)
- **2013** Expanded full 12 month operation
- 2014 2016 Launched centralized capacitor control (base for AMI integration)
- 2017 2018 AMI deployment
- 2018 2019 Integrated AMI for real time voltage operation
- **2020** Full operation of "Dynamic Voltage Reduction" (DVR)

BASIS OF OPERATION



Reduce Voltage -> reduce demand

Terms:

VR: CVR (Conservation) vs DVR (Demand)

"Static" VR – % reduction by modeling – applying static values to operations **"Dynamic"** VR - % reduction automated using real time voltage values

"CVR Ratio" - % demand reduced / % voltage reduced
Will vary depending on load (i.e., resistive heat vs motor)
Connexus measured (weighted average) 0.72
Typical across industry : 0.6 – 0.8

VOLTAGE REDUCTION CONCEPT





Blue – Metered demand Red - Simulated demand - no control CVR ratio .75



J.

PLANNING / ENGINEERING PROCESS (Static)

Base Requirement:

- Maintain voltage at meter > 114 volts (ANSI Range A)
- Connexus model primary voltage minimum 118 volts



REVIEW - VOLT/VAR CONTROL (VVC)





NEW - "DYNAMIC VR" INTEGRATED WITH AMI



BELLWETHER LOCATION STRATEGY





BELLWETHER CONTROL ZONES



BELLWETHER DATA



5 minute "average" voltage readings Transferred every 5 minutes

SCADA "refresh" read and operate – 20 minutes





DVR OPERATION







CONNEXUS TOTAL DEMAND





48 Substation Transformer Base

STATS:	SUMMER	NON-SUMMER
VR range achieved (%)	0-4.0%	0-4.3%
VR system wide weighted average (%)	1.6 - 2.0%	2.0 - 3.0 %
Total System Demand Reduced (%)	1.2 - 1.4%	1.4 - 2.4%



Bellwether meters stop reporting...

Data link from AMI to SCADA breaks...

One meter stops reporting, value goes to zero...

Communications go down??

Receive voltage complaint...



DISTRIBUTION UPGRADES / TECHNOLOGY



Distribution System Improvements to Enhance VR Ability

- Regulators
- Capacitor banks
- **IT Network**
- Alarming Enhancements Bellwether data link, data quality

DVR Operations – Technical Support

Post Operation Analytics





Questions Discussion

